

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 9660-1472:100

Page 1 of 1

CATEGORY: LP Gas Shut-Off Valve

LISTEE: UMAC, Inc., 120 South Ship Road, Exton, PA 19341-2853
Contact: *S. W. Mackay-Smith (610) 524-6800 FAX (610) 524-6806

DESIGN: Models QB-300-075, QB-350-075, GB-350-100, GB-300-075, GB-350-075, GP-350-100, GP-300-075, GP-350-075, GP-350-100, QB-300-100, QB-090-075, QB-150-075, GB-300-100, GB-090-075, GB-150-075, GP-300-100, GP-090-075 and GP-150-075 Gas Excess Flow Shut-Off Valves. The unit is flow regulating with gravity assisted automatic resetting shut-off valves intended for use as gas line service valves suitable for LP-Gas and natural gas where the maximum working pressure does not exceed 5 psig. Refer to listee's data sheet for additional detailed product description and operational considerations. Connection sizes:

-075: 3/4 NPT (inlet) x 3/4 NPT (outlet)
-100: 1 NPT (inlet) x 1 NPT (outlet)

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For vertical installation only.

MARKING: Listee's name, model number, rating and AGA label.

APPROVAL: Listed as LP-gas excess flow shut-off valve for use in gas line at pressure not in excess of 5 psig.

NOTE: These units are not **motion sensitive** valve.

*Rev. 06-05-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 22, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager